

OWS Tiles - 60x60cm Travertine Outdoor Sample Tiles - Wet Sliptest SN070224-8

08 Feb 2024


Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013

This Test Report Is In Accordance with Appendix A	Wet Pendulum Test
Date Tested:	07 Feb 2024
Test Report Number:	SN070224-8
Client Name & Billing Address:	OWS International Building Materials Pty Ltd - Unit1, 17 Pavesi Street, Smithfield NSW 2164
Project Name or Test Location:	Sliptest Australia NSW Headquarters
Surface Tested :	60x60cm Travertine Outdoor Sample Tiles / Anti Slip
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Any Variations to Standards	N/A
Testing Officer / Approved Signatory:	Shenea Neill
Pendulum in use - Calibration Date :	#1133 - Munro-Stanley Portable Skid Tester - (C: 13.10.23 - EN 13036-4)

Signature of Approved Signatory :



Test Results : (Samples and Test Information Supplied by Client)

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN	SCV :	Surface Picture
Area 1	75	75	75	75	75	75	N/A	
Area 2	73	73	73	73	73	73	N/A	
Area 3	75	75	75	74	74	74	N/A	
Area 4	75	75	75	75	75	75	N/A	
Area 5	72	72	72	72	72	72	N/A	

Reported SRV For Test Area : 74

CLASSIFICATION using Slider 96 (4S Slider) P5 = > 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.